

The Synthesis of Soil Resistivity and EMF of underground Cable combined with 3-D Electromagnetic Field Study in Analyzing the Grounding Touch

Jeu-Min Lin

Graduated Ph.D. student, Department of Electrical Engineering

National Cheng Kung University

Tainan, Taiwan

E-mail address: jeumin@gmail.com

Abstract

The earthing analysis is proposed in this paper. The effects of 3-D electromagnetic field and the influences of stray current are considered in the text simultaneously. The activity in the high-voltage environment is risky of being injured by electric shock. The safety of personnel in and around electric power the installations has been a prime concern. Specially, the safety is generally in terms of the allowable touch and step voltages. These voltages are related to the earthing resistance of human foot. In order to increase the safety of personnel, a high resistivity surface layer of gravel is normally existed in the substation switchyards or other high voltage areas. The thickness of this layer will affect the calculation of the earthing resistance of human foot. Thus, the effect of soil resistivity will be considered in this paper. Among them, the electromagnetic field and humidity factors are also considered in this paper. As a result, the surface layer of gravel can be used to reduce the earthing resistance of human foot. The equivalent model of human foot was modeled by the circular plate conductor in the past. Which consider the beauty of the environment, most of the transmission lines are in the surface, so the transmission line generated by the discrete current will affect the earthing resistance estimation, thus the proposed paper will consider the composition of the special function which is the mathematical calculus popularized by the basic theorem of calculus. On the other hand, the damp ingredients, temperatures, and soil resistivity on the surface will also be considered in this paper. This paper research into the proposed method for estimating the earthing resistance of human foot and proposes an equivalent model for calculating the grounding resistance of human foot. The comparisons of the method are also shown in this paper.

Keywords: Earthing analysis, 3-D electromagnetic field, stray current, soil resistivity, earthing, resistance estimation, attenuation element, step voltage, contact voltage, body earthing resistance, electromagnetic field elements, underground cable, and damp ingredients.

I. INTRODUCTION

In the high voltage environments, such as work in the substations or railway dispatching places, high voltage electric towers side, or Underground Railroad track sides, the ground surface is usually evenly covered with a layer of 8 to 25cm thickness of gravel, to increase the soil and the contact

resistance between the feet (Contact Resistance). Assuming that the equivalent resistance of the shoes and socks is zero, the contact resistance is the equivalent resistance of the gravel layer. Because the contact resistance between the soil layer and the foot is large, when the accident occurs (for example, the hand touches the lightning striking device), the current flowing through the body will be much smaller than

the absence of the gravel layer, in other words, The contact voltage or step voltage suffered by the human body will be smaller. In this way, we can ensure the safety of the site workers.

In the calculation of the human body can withstand the contact voltage or step voltage, the foot of the ground resistance is a very important factor. In general, the human foot is often equivalent to a circular plate Conductor with a radius of 8 cm. According to the IEEE standard 80, a circular plate-like conductor having a radius b is placed on a soil having a resistivity ρ_s (assuming a fairly uniform distribution of the resistivity distribution), and the ground resistance R_f thereof can be expressed as follows [1]:

$$R_f = \frac{\rho_s}{4b} \quad (1)$$

Where $b = 0.08$ m

$$R_f \approx 3\rho_s \quad (2)$$

Since the size of the gravel layer is large enough, it is possible to assume that the resistivity of the material in the foot is uniform in the horizontal direction. However, compared with the equivalent radius of the foot (0.08 m), the thickness of the gravel layer is not large enough, so the resistivity of the material to which the foot is exposed is not uniform in the vertical direction. If the high resistivity gravel is laid on a low resistivity soil, this will cause the ground resistance of the foot to be lower than equation (1). At this time, the ground resistance of the foot can be expressed as follows [2]:

$$R_f = \frac{\rho_c}{4b} C \quad (3)$$

Where ρ_c = the resistivity of the gravel layer

C = attenuation factor

The paper should note that if you consider the gravel

layer, in the ground resistance, the IEEE standard 80 has derived the earthing resistance of the infinite series expression (Infinite Series Expression). However, in the reference [8], this infinite series is deduced into a finite expression. The ground resistors calculated by the two representations are quite close, but the finite term expressions are more convenient to use. The structure of this paper is as follows: The method of calculating the earthing resistance of the human body foot will be described in Section 2, and then we will briefly introduce the method mentioned in this paper and the simulation results listed in Section IV. Finally, it is the conclusion of this paper

II. THE EXISTING CALCULATION OF THE HUMAN BODY

According to the IEEE standard 80, the foot is equivalent to a circular plate-shaped conductor with a radius b and placed on a double-layer medium. The first layer is a gravel of resistivity ρ_c , the second layer is a soil with resistivity ρ_s , the ground resistance R_f of the foot can be expressed as follows [1]:

$$R_f = \frac{\rho_c}{4b} F(x) \quad (4)$$

$$F(x) = 1 + 2 \sum_{n=1}^{\infty} \frac{K^n}{\sqrt{1 + (2nX)^2}} \quad (5)$$

$$K = \frac{\rho_s - \rho_c}{\rho_s + \rho_c} \quad (6)$$

Where ρ_c = the resistivity of the gravel layer

ρ_s = resistivity of soil layer

$X = h / b$

H = thickness of gravel layer

B = equivalent radius of the foot (0.08 m)

K = Reflection Factor

According to the hemispherical electrode (Hemispherical Electrode) resistance method, and the use of virtual image method (Method of Image) [2], can be derived equations (4), (5) and (6). In order to simplify the complex mathematical operations, so in the derivation of the process made some assumptions, but this has caused the equation produced an error. Especially when h smaller, the error will be greater [5]. As can be seen from the past figures and literatures, the slope of the curve increases as h decreases, but when h is small, the slope of the curve is reduced.

In another method of earthing resistance, the equivalent model of the foot is also a circular plate conductor, but the derivation method is different from the derivation method of the IEEE standard 80 equation.

If the foot is equivalent to a radius of b ($= 0.08m$) of the circular plate-like conductor, placed in the resistivity ρ_s on the soil (assuming a fairly uniform distribution of resistivity), the earthing resistance can be expressed as follows [1]:

$$R_f = \frac{\rho_s}{4b} \quad (7)$$

If the gravel layer is considered, the ground resistance can be expressed as follows [3, 4, 5]:

$$R_f = \frac{\rho_c}{4b} H(x) \quad (8)$$

$$H(x) = 1 + \frac{4}{\pi} \sum_{n=1}^{\infty} P \quad (9)$$

$$P \approx \frac{K^n}{2nx} \left[1 - \frac{7}{12} \frac{1}{(2nx)^2} + \frac{33}{40} \frac{1}{(2nx)^4} \right] \quad (10)$$

$$K = \frac{\rho_s - \rho_c}{\rho_s + \rho_c} \quad (11)$$

When $(2h) / b > 3.5$ or $h > 0.14m$, the values obtained by Equations (8) and (9) are more accurate. Appendix A can be referred for restrictions on this scope.

Then, the design can be synthesized with ease that transfers the descriptions to gate-level net lists without further effort.

III. THE PROPOSED METHOD

In this paper, Fig. 1 is a plate-like conductor is placed on a double-layer medium, the first layer is a gravel of resistivity ρ_c , and the second layer is a soil with resistivity ρ_s . Among them, the gravel layer thickness h . We can use the virtual image method we can get plate-like conductor and its mirror (Images) position distribution. Assuming that the ground current of the plate conductor is I , if the boundary between the air and the gravel layer is the mapping interface, the Current is not the same; if the boundary between the soil layer and the gravel layer As the mapping interface, then the current will be proportional to the power of the reflection factor K , as shown in Fig. 2. Where $K = (\rho_s - \rho_c) / (\rho_s + \rho_c)$. The resistivity of all the regions in Fig. 4 is ρ_c [10], whether the plate conductor itself or its mirror is discharged to the gravel layer with resistivity ρ_c .




Fig. 1 Schematic representation of a square plate conductor in a gravel layer




Fig. 2 Square plate-like mapping architecture




Fig. 3 The diagram of magnetic field

Using the superposition principle (Superposition Theorem), the average potential V_{ave} of the plate-like conductor can be obtained as follows, which also consider the factors of electromagnetic field in the proposed paper. Fig. 3 shows a schematic view of the magnetic field lines displayed through the iron powder on the white paper, which is known that the pure quantity of the electromagnetic field function has an important influencing factor on the creatures. On the other hand, this paper considers the electromotive force generated by electrostatic charge in space, so that [11]:

$$V_p = 2\pi r \sigma \left[\sinh^{-1} \frac{\beta \ell}{d} + \sinh^{-1} \frac{(1-\beta)\ell}{d} \right]$$

(12)

Where r = the radius of the wire,

σ = surface charge density.

$$V_{ave} = 2IR + 4KIR_{m(2h)} + 4K^2IR_{m(4h)} + \dots$$

$$= I \left[2R + 4 \sum_{n=1}^{\infty} K^n R_{m(2nh)} \right] + \rho \quad (13)$$

$$R_{fpprox, \rho_s} \quad (14)$$

$$R_p = \frac{V_{ave}}{I} = 2R + 4 \sum_{n=1}^{\infty} K^n R_{m(2nh)} \quad (15)$$

Where R = plate-like conductor earthing resistance obtained in a uniform medium of resistivity ρ_c

$R_m(2_{nh})$ = mutual resistance of two parallel plate-like conductors spaced 2_{nh} apart in a uniform medium of resistivity ρ_c
 (Mutual Ground Resistance)

ρ = Volume charge density

∇ = gradient operator

\mathbf{D} = electric flux density

\cdot = dot operator

It was known that power system consists of two units of active power and reactive power, and the amount of power is the area surrounded by the active and reactive work function on the graph. Therefore, this proposed paper has been considered the energy which is generated by the Green's function [13]. This function is a known vector calculus theorem which is shown in eq. (16), to maintain the law of conservation of energy [14].

$$\oint Pdx + Qdy = \int \int_R dA \quad (16)$$

Where c is a closed smooth curve on a plane and the area around it is, supposing the function P (x, y) and Q (x, y) are continuous and one partial derivative is continuous, the equation holds as discussed Green's function, and variables P

and Q exist in the R field. In other words, the Green's function has to be considered in eq. (13).

On the other hand, if the potential problem of electrostatic charge in the electric field space is considered in this paper, the potential at space satisfies Poisson's function. So equation (13) must be reconsidered the composition of $\nabla^2 \mathbf{u} = -\rho / \epsilon$, which is called by Poisson's equation [12].

Based on the previous studies, it is known that the factors of humidity and temperature of the environment are the great influence elements of the resistance estimation. According to the literatures, the resistance estimation and the relationship between humidity and temperature are exponential functions, as shown below:

$$R = R_0 \exp \alpha (\Phi - \Phi_0) - R_t \exp \beta (t - t_0) \quad (17)$$

, where R_0 = initial resistance,

t_0 = initial temperature,

α = humidity constant,

Φ = wetting coefficient,

Φ_0 = initial value of the wetting coefficient

R_t = starting resistance

β = temperature constant.

Assuming that the length of the strip conductor is ℓ , the width is a and the thickness is b, the ground resistance R of the strip conductor in the uniform medium of the resistivity ρ_c is as follows [10]:

$$R = \frac{\rho_c}{2\pi\ell} \left[\ln \frac{2\ell}{a} + \frac{a^2 - \pi ab}{2(a+b)^2} \right] \quad (18)$$

When the width a is much larger than the thickness b and the length is equal to the width a, the ribbon conductor can be regarded as a square plate conductor,

$$R \approx 0.5966 \frac{\rho_c}{\pi\ell} \quad (19)$$

$$V_p = 2\pi r \sigma \left[\sinh^{-1} \frac{\beta \ell}{d} + \sinh^{-1} \frac{(1-\beta)\ell}{d} \right] \quad (20)$$

Where r = radius of the wire,
 Σ = surface charge density




Fig. 4 The geometric position on the two parallel lines

As shown in Fig. 4, the two metal lines are long and spaced apart from each other. If the surface charge distribution of the metal line AB is uniform, the potential V_p at any point on the wire CD can be expressed as

$$V_p = 2\pi r \sigma \left[\sinh^{-1} \frac{\beta \ell}{d} + \sinh^{-1} \frac{(1-\beta)\ell}{d} \right] \quad (21)$$

Where r = the radius of the wire, σ = surface charge density.
 The average potential V_{ave} of the metal wire CD is :

$$\begin{aligned} V_{ave} &= 2\pi r \sigma \int_0^1 \left[\sinh^{-1} \frac{\beta \ell}{d} + \sinh^{-1} \frac{(1-\beta)\ell}{d} \right] d\beta \\ &= 4 \pi r \sigma \left(\sinh^{-1} \frac{\ell}{d} - \sqrt{1 + \frac{d^2}{\ell^2}} + \frac{d}{\ell} \right) \\ &= \frac{2Q}{\ell} \left(\sinh^{-1} \frac{\ell}{d} - \sqrt{1 + \frac{d^2}{\ell^2}} + \frac{d}{\ell} \right) \quad (22) \end{aligned}$$

Where Q = total charge of metal line AB.

Since the square plate-like conductor can be visually composed of an infinite number of metal wires, the average potential caused by a charged square-shaped conductor on the

other square-shaped conductor is also equation (18). So the mutual resistance $R_{m(d)}$ can be expressed as [9]:

$$\begin{aligned} R_{m(d)} &= \frac{\rho_c}{4\pi C} = \frac{\rho_c}{4\pi} \frac{V_{ave}}{Q} \\ &= \frac{\rho_c}{2\pi \ell} \left(\sinh^{-1} \frac{\ell}{d} - \sqrt{1 + \frac{d^2}{\ell^2}} + \frac{d}{\ell} \right) \quad (23) \end{aligned}$$

Where ρ_c = the resistivity of the environment in which the conductor is located.

Therefore, the resistance of the two-sided plate-shaped conductor at a distance of $2nh$ is

$$\begin{aligned} R_{m(2nh)} &= \frac{\rho_c}{2\pi \ell} \left(\sinh^{-1} \frac{\ell}{2nh} - \sqrt{1 + \frac{(2nh)^2}{\ell^2}} \right. \\ &\quad \left. + \frac{2nh}{\ell} \right) \quad (24) \end{aligned}$$

Equations (15) and (23) are substituted into Equation (13), so that the ground resistance R_f after the equivalent of a square plate-like conductor can be obtained as follows:

$$R_f = 1.1931 \frac{\rho_c}{\pi \ell} S(y) \quad (25)$$

$$S(y) = 1 + 1.6762 \sum_{n=1}^{\infty} T \quad (26)$$

$$T = K^n \left[\sinh^{-1} \frac{1}{2ny} + 2ny - \sqrt{(2ny)^2 + 1} \right] \quad (27)$$

$$K = (\rho_s - \rho_c) / (\rho_s + \rho_c) \quad (28)$$

Where ρ_c = the resistivity of the gravel layer,

ρ_s = resistivity of soil layer,

h = thickness of gravel layer,

ℓ = Side length of square plate conductor,

$y = h / \ell$,

K = reflection factor

By the way in this paper, when $(2h) / \ell > 1$, the values obtained by equations (23) and (24) are more accurate.

IV. THE SIMULATED TESTS

If the coefficient ($\rho_c / 4b$) of equation (25) is equal to the coefficient of equation (25) ($1.1931\rho_c / \pi$), $= 0.1215m$. In this way, when $h > 0.06m$, the value obtained by equation (22) is more accurate. Therefore, when K is equal to $-0.2, -0.4, -0.6, -0.8$, the relationship between $S(y)$ and h is shown in Fig. 5. If $\rho_s = 100 [\Omega\cdot m]$, K is equal to $0, -0.1, -0.2, \dots, -0.9$, the relationship between R_f and h is shown in Fig. 6. We can see from Fig. 5 the following described the phenomenon. When the thickness of the gravel layer remains constant, the ground resistance of the foot decreases as the reflection factor increases. When the reflection factor remains constant, the ground resistance of the foot decreases as the thickness of the gravel layer decreases. Table 1 shows the comparison of the respective attenuation factors. To observe these data, we find that $S(y)$ is quite close to $H(x)$ and in any case $F(x)$ is less than $H(x)$ and $S(y)$. In addition, when $K = 0$, regardless of h for several, the attenuation factor is 1. Since $K = 0$ means that the resistivity of the soil layer is the same as that of the gravel layer. Therefore, regardless of any of the earthing resistance formula in this paper, the value obtained is equal with. On the other hand, we can also find that the effect of $K = 0$ is exactly the same as $h = 0$ and the resistivity of the soil layer is equal to the resistivity of the gravel layer.




Fig. 5 The map of the relationships of $S(y)$, h and K




Fig. 6 The map of the relationships of R_f and h , K relation

Table 1 A comparison table of attenuation factor

K	h(cm)	F(x)	H(x)	S(y)
0	6	1	$\Rightarrow \Rightarrow$	1
0	10	1	$\Rightarrow \Rightarrow$	1
0	14	1	1	1
0	20	1	1	1
0	24	1	1	1
-0.1	6	0.895033	$\Rightarrow \Rightarrow$	0.924715
-0.1	10	0.929441	$\Rightarrow \Rightarrow$	0.952914
-0.1	14	0.947730	0.966839	0.965953
-0.1	20	0.962622	0.976335	0.975926
-0.1	24	0.977524	0.977052	0.975981
-0.3	6	0.714517	$\Rightarrow \Rightarrow$	0.793737
-0.3	10	0.806635	$\Rightarrow \Rightarrow$	0.870532
-0.3	14	0.856418	0.909034	0.906141
-0.3	20	0.897346	0.934816	0.933715
-0.3	24	0.938271	0.954819	0.961718
-0.5	6	0.563943	$\Rightarrow \Rightarrow$	0.682433
-0.5	10	0.702546	$\Rightarrow \Rightarrow$	0.800239

-0.5	14	0.778711	0.859746	0.855117
-0.5	20	0.841525	0.899416	0.897625
-0.5	24	0.917691	0.939418	0.899727
-0.7	6	0.435335	↔↔	0.586038
-0.7	10	0.612433	↔↔	0.738949
-0.7	14	0.711018	0.816825	0.810543
-0.7	20	0.792814	0.868511	0.866124
-0.7	24	0.799813	0.908506	0.868126
-0.9	6	0.323722	↔↔	0.50097
-0.9	10	0.533029	↔↔	0.684634
-0.9	14	0.651131	0.778934	0.770922
-0.9	20	0.749615	0.841116	0.838121
-0.9	24	0.798857	0.872585	0.860529

Marks: F(x) is the attenuation factor of IEEE standard 80.,
 H(x) is the attenuation factor of the circular plate
 conductor, and
 S(y) is the attenuation factor of the square plate
 conductor.

V. CONCLUSIONS

Through the discussions of this paper and the related simulation experiments, the following conclusions can be summarized:

- (a.) If the surface covered with a layer of high resistivity gravel, can increase the contact resistance between the soil and feet. Because the contact between the soil layer and the foot is very large, so when the accident occurs, the current through the body than the absence of gravel layer is much smaller. Therefore, covered with gravel can improve the safety of the site staff.
- (b.) When the reflection factor remains constant, the attenuation factor decreases as the thickness of the gravel layer decreases. On the other hand, the contact voltage or step voltage is proportional to the ground resistance, so the thickness of the gravel layer is thinner, the human body will

suffer the step voltage or contact voltage will be smaller. See Appendix B for details.

(c.) When the thickness of the gravel layer remains constant, the attenuation factor increases as the reflection factor increases. So the greater the reflection factor, the human body suffered by the step voltage or contact voltage will be smaller. See Appendix C. for details.

(d.) The attenuation factor S(y) and H(x) are quite close to each other, the error is less than 1.2%. Therefore, the formulas presented in this paper are quite accurate compared with those in the references. And the use range of S(y) (the thickness of the gravel layer) is larger than that of H(x).

(e.) (Y) / F(x) in any case, the attenuation factor F(x) is less than S(y) and H(x), especially when $K < -0.9$ and $h < 10\text{cm}$, The In addition, due to the inaccuracy of the equation in IEEE Standard 80, the ground resistance standard set by it is somewhat conservative compared to other literature and this text.

(f.) With the discussions of the proposed paper, this content can enhance and ensure the personal safety.

(g.) Based on the Kirchhoff's law, if the resistance remains constant, the greater the voltage, the greater the current, making the larger the electromagnetic field. In other words, the phenomenon will affect the health of human being.

(h.) According to the medical literatures, as time changes, high electromagnetic fields can affect the responses of human physiology and psychology.

(i.) According to Coulomb's Law, it is known that the interaction between the two stationary point charges in vacuum is inversely proportional to the square of the distance. In other words, the impact of overhead lines or substations is almost zero.

(j.) Known wire has resistance and inductance and capacitance, the impedance is the sum of the resistance and reactance in the vector, the resistance can be ignored at low current, and the inductance can be ignored at low

$$\frac{aV_{ave,s}}{Q} = \frac{a}{s} \left(1 + \frac{7}{24} \frac{a^2}{s^2} + \frac{99}{320} \frac{a^4}{s^4} + \dots \right) \quad (B.2)$$

When $s/a > 3.5$, (B.1) and (B.2) in the $s/a > 3.5$ will approach a similar value, so

$$\frac{V_{ave,p}}{Q} = \frac{V_{ave,s}}{Q} \quad (B.3)$$

$$\text{And } R = \frac{\rho}{4\pi} \frac{V}{Q} \quad (B.4)$$

Therefore, $R_p = R_s$. Where R_p = the mutual resistance at different planes, R_s = the mutual resistance at the same plane [10]. Therefore, when the authors choose $(2h)/b > 3.5$, the proposed paper will improve the accuracy of equations (8) and (9). Similarly, if $(2h)/b > 1$ is chosen, the values obtained from equations (20) and (21) will be more accurate.

Appendix C

When the thickness of the gravel layer is constant, the attenuation factor increases as the reflection factor increases. From the equation (A.1) we can see that the earthing resistance and the reflection factor and attenuation factor. However, when the reflection factor is increased, the rate of decrease of $1-K / 1 + K$ is greater than the rate of increase of the attenuation factor, so that the earthing resistance is reduced. For example, when $h = 20\text{cm}$, when $K = -0.9$, then $S(y) = 0.8381$, $1-K / 1 + K = 19$, if K rises to -0.7 , then $S(y) = 0.8661$, $K / 1 + K = 5.6667$. It can be seen, if the reflection factor increases, will result in reduced earthing resistance, so the human body suffered by the step voltage or contact voltage will be reduced.